

Prairie Island 1

4Q/2000 Performance Indicators

Licensee's General Comments: none

Unplanned Scrams per 7000 Critical Hrs



Thresholds: White > 3.0 Yellow > 6.0 Red > 25.0

Notes

Unplanned Scrams per 7000 Critical Hrs	4Q/99	1Q/00	2Q/00	3Q/00	4Q/00
Unplanned scrams	0	0	0	0	0
Critical hours	2209.0	2184.0	2183.0	2208.0	1930.8
Indicator value	0.9	0	0	0	0

Licensee Comments: none

Scrams with Loss of Normal Heat Removal




Thresholds: White > 2.0 Yellow > 10.0 Red > 20.0

Notes

Scrams with Loss of Normal Heat Removal	4Q/99	1Q/00	2Q/00	3Q/00	4Q/00
Scrams	0	0	0	0	0
Indicator value	2.0	2.0	2.0	2.0	2.0

Licensee Comments: none

Unplanned Power Changes per 7000 Critical Hrs




Thresholds: White > 6.0

Notes

Unplanned Power Changes per 7000 Critical Hrs	4Q/99	1Q/00	2Q/00	3Q/00	4Q/00
Unplanned power changes	0	0	0	0	0
Critical hours	2209.0	2184.0	2183.0	2208.0	1930.8
Indicator value	0	0	0	0	0

Licensee Comments: none

Safety System Unavailability, Emergency AC Power



Thresholds: White > 2.5% Yellow > 5.0% Red > 10.0%

Notes

Safety System Unavailability, Emergency AC Power	4Q/99	1Q/00	2Q/00	3Q/00	4Q/00
Train 1					
Planned unavailable hours	10.38	18.52	10.30	11.04	33.57
Unplanned unavailable hours	0	0	11.37	0	23.37
Fault exposure hours	0	0	0	0	0
Effective Reset hours	0	0	0	0	0
Required hours	2209.00	2184.00	2183.00	2208.00	2209.00
Train 2					
Planned unavailable hours	10.17	15.85	10.49	14.10	30.52
Unplanned unavailable hours	0	0	0	0	7.50
Fault exposure hours	0	0	0	0	0
Effective Reset hours	0	0	0	0	0
Required hours	2209.00	2184.00	2183.00	2208.00	2209.00
Indicator value	1.3%	1.3%	1.3%	1.2%	1.2%

Licensee Comments:

4Q/00: An old design error was identified in the 4Q2000 (LER 1-00-04) on a support system (service water pumps). Due to bearing water supply to the pumps being unqualified, the pumps were administratively declared inoperable. Having all three pumps inoperable, caused us to enter into Technical Specifications 3.0.c. A Notice Of Enforcement Discretion (NOED) was requested and granted to allow continued operation until a qualified bearing water system could be installed. In particular, qualification of the bearing water supply was lacking with respect to two initiating events: (1) LOOP, and (2) seismic event. Compensatory measures were put in place to increase the likelihood that the bearing water would be supplied in the event of a LOOP or seismic event (during the period of the NOED). At this time, we are conservatively including 299.33 hours of unplanned unavailability to this mitigating system. An FAQ has been submitted to request clarification on reporting requirements for this event.

4Q/00: An old design error was identified in the 4Q2000 (LER 1-00-04) on a support system (service water pumps). Due to bearing water supply to the pumps being unqualified, the pumps were administratively declared inoperable. Having all three pumps inoperable, caused us to enter into Technical Specifications 3.0.c. A Notice Of Enforcement Discretion (NOED) was requested and granted to allow continued operation until a qualified bearing water system could be installed. In particular, qualification of the bearing water supply was lacking with respect to two

1Q/00: Planned unavailable hours for 3Q96, 2Q97, 2Q98, 3Q99, and 1Q2000 were revised to reflect current guidance of NEI 99-02, rev. 0, which states that planned overhaul hours do not have to be included in the unavailable hours for this performance indicator. NEI 99-02 allows data, submitted prior to revision 0, may be revised and resubmitted to reflect current guidance if desired. During a review of data for removal of the overhaul hours, a 0.1 hour data error was identified for 3Q96 Train 2 planned unavailable hours. Planned hours reported were 90.75 and should have been 90.85. This was corrected with this change. The changes did not result in a threshold color change.

Thresholds: White > 1.5% Yellow > 5.0% Red > 10.0%

--	--	--	--	--	--

Safety System Unavailability, High Pressure Injection System (HPSI)	4Q/99	1Q/00	2Q/00	3Q/00	4Q/00
Train 1					
Planned unavailable hours	2.16	18.72	0.87	12.53	1.32
Unplanned unavailable hours	0	0	17.05	20.93	4.50
Fault exposure hours	0	0	0	0	0
Effective Reset hours	0	0	0	0	0
Required hours	2209.00	2184.00	2183.00	2208.00	1930.80
Train 2					
Planned unavailable hours	2.03	0.99	1.21	19.23	1.80
Unplanned unavailable hours	0	0	0	0	7.50
Fault exposure hours	0	0	0	0	0
Effective Reset hours	0	0	0	0	0
Required hours	2209.00	2184.00	2183.00	2208.00	1930.80
Indicator value	0.3%	0.4%	0.4%	0.5%	0.4%

Licensee Comments:


4Q/00: An old design error was identified in the 4Q2000 (LER 1-00-04) on a support system (service water pumps). Due to bearing water supply to the pumps being unqualified, the pumps were administratively declared inoperable. Having all three pumps inoperable, caused us to enter into Technical Specifications 3.0.c. A Notice Of Enforcement Discretion (NOED) was requested and granted to allow continued operation until a qualified bearing water system could be installed. In particular, qualification of the bearing water supply was lacking with respect to two initiating events: (1) LOOP, and (2) seismic event. Compensatory measures were put in place to increase the likelihood that the bearing water would be supplied in the event of a LOOP or seismic event (during the period of the NOED). At this time, we are conservatively including 299.33 hours of unplanned unavailability to this mitigating system. An FAQ has been submitted to request clarification on reporting requirements for this event. New Comment (4/23/01) Change resulted in addition of 0.42 hours of unavailability time to Train 1 for 4Q00 as a result of review/discussion with other utility. This change did not result in a threshold color change. New Comment (7/18/01) Revised the unplanned unavailability hours reported for 4Q2000 based on approval of FAQ 278 on 7/12/2001. This change resulted in a color change from WHITE to GREEN.

4Q/00: An old design error was identified in the 4Q2000 (LER 1-00-04) on a support system (service water pumps). Due to bearing water supply to the pumps being unqualified, the pumps were administratively declared inoperable. Having all three pumps inoperable, caused us to enter into Technical Specifications 3.0.c. A Notice Of Enforcement Discretion (NOED) was requested and granted to allow continued operation until a qualified bearing water system could be installed. In particular, qualification of the bearing water supply was lacking with respect to two initiating events: (1) LOOP, and (2) seismic event. Compensatory measures were put in place to increase the likelihood that the bearing water would be supplied in the event of a LOOP or seismic event (during the period of the NOED). At this time, we are conservatively including 299.33 hours of unplanned unavailability to this mitigating system. An FAQ has been submitted to request clarification on reporting requirements for this event.

4Q/00: An old design error was identified in the 4Q2000 (LER 1-00-04) on a support system (service water pumps). Due to bearing water supply to the pumps being unqualified, the pumps were administratively declared inoperable. Having all three pumps inoperable, caused us to enter into Technical Specifications 3.0.c. A Notice Of Enforcement Discretion (NOED) was requested and granted to allow continued operation until a qualified bearing water system could be installed. In particular, qualification of the bearing water supply was lacking with respect to two initiating events: (1) LOOP, and (2) seismic event. Compensatory measures were put in place to increase the likelihood that the bearing water would be supplied in the event of a LOOP or seismic event (during the period of the NOED). At this time, we are conservatively including 299.33 hours of unplanned unavailability to this mitigating system. An FAQ has been submitted to request clarification on reporting requirements for this event. New Comment (4/23/01) Change resulted in addition of 0.42 hours of unavailability time to Train 1 for 4Q00 as a result of review/discussion with other utility. This change did not result in a threshold color change. New Comment (7/18/01) Revised the unplanned unavailability hours reported for 4Q2000 based on approval of FAQ 278 on 7/12/2001. This change resulted in a color change from WHITE to GREEN.

4Q/00: An old design error was identified in the 4Q2000 (LER 1-00-04) on a support system (service water pumps). Due to bearing water supply to the pumps being unqualified, the pumps were administratively declared inoperable. Having all three pumps inoperable, caused us to enter into Technical Specifications 3.0.c. A Notice Of Enforcement Discretion (NOED) was requested and granted to allow continued operation until a qualified bearing water system could be installed. In particular, qualification of the bearing water supply was lacking with respect to two initiating events: (1) LOOP, and (2) seismic event. Compensatory measures were put in place to increase the likelihood that the bearing water would be supplied in the event of a LOOP or seismic event (during the period of the NOED). At this time, we are conservatively including 299.33 hours of unplanned unavailability to this mitigating system. An FAQ has been submitted to request clarification on reporting requirements for this event. New Comment (4/23/01) Change resulted in addition of 0.42 hours of unavailability time to Train 1 for 4Q00 as a result of review/discussion with other utility. This change did not result in a threshold color change.

Safety System Unavailability, Heat Removal System (AFW)



Thresholds: White > 2.0% Yellow > 6.0% Red > 12.0%

Notes

Safety System Unavailability, Heat Removal System (AFW)	4Q/99	1Q/00	2Q/00	3Q/00	4Q/00
Train 1					
Planned unavailable hours	8.28	15.46	6.36	8.56	31.77
Unplanned unavailable hours	17.94	0	11.37	0	4.50
Fault exposure hours	0	0	0	0	0
Effective Reset hours	0	0	0	0	0
Required hours	2209.00	2184.00	2183.00	2208.00	1930.80
Train 2					
Planned unavailable hours	5.84	6.24	7.65	5.79	10.22
Unplanned unavailable hours	0	0	0	0	7.50
Fault exposure hours	0	0	0	0	0
Effective Reset hours	0	0	0	0	0
Required hours	2209.00	2184.00	2183.00	2208.00	1930.80
Indicator value	0.8%	0.8%	0.7%	0.7%	0.6%

Licensee Comments:


4Q/00: An old design error was identified in the 4Q2000 (LER 1-00-04) on a support system (service water pumps). Due to bearing water supply to the pumps being unqualified, the pumps were administratively declared inoperable. Having all three pumps inoperable, caused us to enter into Technical Specifications 3.0.c. A Notice Of Enforcement Discretion (NOED) was requested and granted to allow continued operation until a qualified bearing water system could be installed. In particular, qualification of the bearing water supply was lacking with respect to two initiating events: (1) LOOP, and (2) seismic event. Compensatory measures were put in place to increase the likelihood that the bearing water would be supplied in the event of a LOOP or seismic event (during the period of the NOED). At this time, we are conservatively including 299.33 hours of unplanned unavailability to this mitigating system. An FAQ has been submitted to request clarification on reporting requirements for this event.

4Q/00: An old design error was identified in the 4Q2000 (LER 1-00-04) on a support system (service water pumps). Due to bearing water supply to the pumps being unqualified, the pumps were administratively declared inoperable. Having all three pumps inoperable, caused us to enter into Technical Specifications 3.0.c. A Notice Of Enforcement Discretion (NOED) was requested and granted to allow continued operation

until a qualified bearing water system could be installed. In particular, qualification of the bearing water supply was lacking with respect to two initiating events: (1) LOOP, and (2) seismic event. Compensatory measures were put in place to increase the likelihood that the bearing water would be supplied in the event of a LOOP or seismic event (during the period of the NOED). At this time, we are conservatively including 299.33 hours of unplanned unavailability to this mitigating system. An FAQ has been submitted to request clarification on reporting requirements for this event. New Comment (7/18/01) Revised the unplanned unavailability hours reported for 4Q2000 based on approval of FAQ 278 on 7/12/2001. This change did not result in a color change. The indicator remained GREEN.

4Q/00: An old design error was identified in the 4Q2000 (LER 1-00-04) on a support system (service water pumps). Due to bearing water supply to the pumps being unqualified, the pumps were administratively declared inoperable. Having all three pumps inoperable, caused us to enter into Technical Specifications 3.0.c. A Notice Of Enforcement Discretion (NOED) was requested and granted to allow continued operation until a qualified bearing water system could be installed. In particular, qualification of the bearing water supply was lacking with respect to two initiating events: (1) LOOP, and (2) seismic event. Compensatory measures were put in place to increase the likelihood that the bearing water would be supplied in the event of a LOOP or seismic event (during the period of the NOED). At this time, we are conservatively including 299.33 hours of unplanned unavailability to this mitigating system. An FAQ has been submitted to request clarification on reporting requirements for this event. New Comment (7/18/01) Revised the unplanned unavailability hours reported for 4Q2000 based on approval of FAQ 278 on 7/12/2001. This change did not result in a color change. The indicator remained GREEN.

Safety System Unavailability, Residual Heat Removal System



Thresholds: White > 1.5% Yellow > 5.0% Red > 10.0%

Notes

Safety System Unavailability, Residual Heat Removal System	4Q/99	1Q/00	2Q/00	3Q/00	4Q/00
Train 1					
Planned unavailable hours	6.05	9.03	0.99	25.74	13.26
Unplanned unavailable hours	0	0	17.05	0	4.50
Fault exposure hours	0	0	0	0	0
Effective Reset hours	0	0	0	0	0
Required hours	2209.00	2184.00	2183.00	2208.00	2209.00
Train 2					
Planned unavailable hours	3.53	1.06	1.29	29.67	2.66

Unplanned unavailable hours	0	0	0	0	7.50
Fault exposure hours	0	0	0	0	0
Effective Reset hours	0	0	0	0	0
Required hours	2209.00	2184.00	2183.00	2208.00	2209.00
Indicator value	0.5%	0.5%	0.5%	0.6%	0.5%

Licensee Comments:


4Q/00: An old design error was identified in the 4Q2000 (LER 1-00-04) on a support system (service water pumps). Due to bearing water supply to the pumps being unqualified, the pumps were administratively declared inoperable. Having all three pumps inoperable, caused us to enter into Technical Specifications 3.0.c. A Notice Of Enforcement Discretion (NOED) was requested and granted to allow continued operation until a qualified bearing water system could be installed. In particular, qualification of the bearing water supply was lacking with respect to two initiating events: (1) LOOP, and (2) seismic event. Compensatory measures were put in place to increase the likelihood that the bearing water would be supplied in the event of a LOOP or seismic event (during the period of the NOED). At this time, we are conservatively including 299.33 hours of unplanned unavailability to this mitigating system. An FAQ has been submitted to request clarification on reporting requirements for this event. New Comment (7/18/01) Revised the unplanned unavailability hours reported for 4Q2000 based on approval of FAQ 278 on 7/12/2001. This change resulted in a color change from WHITE to GREEN.

4Q/00: An old design error was identified in the 4Q2000 (LER 1-00-04) on a support system (service water pumps). Due to bearing water supply to the pumps being unqualified, the pumps were administratively declared inoperable. Having all three pumps inoperable, caused us to enter into Technical Specifications 3.0.c. A Notice Of Enforcement Discretion (NOED) was requested and granted to allow continued operation until a qualified bearing water system could be installed. In particular, qualification of the bearing water supply was lacking with respect to two initiating events: (1) LOOP, and (2) seismic event. Compensatory measures were put in place to increase the likelihood that the bearing water would be supplied in the event of a LOOP or seismic event (during the period of the NOED). At this time, we are conservatively including 299.33 hours of unplanned unavailability to this mitigating system. An FAQ has been submitted to request clarification on reporting requirements for this event. New Comment (7/18/01) Revised the unplanned unavailability hours reported for 4Q2000 based on approval of FAQ 278 on 7/12/2001. This change resulted in a color change from WHITE to GREEN.

4Q/00: An old design error was identified in the 4Q2000 (LER 1-00-04) on a support system (service water pumps). Due to bearing water supply to the pumps being unqualified, the pumps were administratively declared inoperable. Having all three pumps inoperable, caused us to enter into Technical Specifications 3.0.c. A Notice Of Enforcement Discretion (NOED) was requested and granted to allow continued operation until a qualified bearing water system could be installed. In particular, qualification of the bearing water supply was lacking with respect to two initiating events: (1) LOOP, and (2) seismic event. Compensatory measures were put in place to increase the likelihood that the bearing water would be supplied in the event of a LOOP or seismic event (during the period of the NOED). At this time, we are conservatively including 299.33 hours of unplanned unavailability to this mitigating system. An FAQ has been submitted to request clarification on reporting requirements for this event.

2Q/99: The RHR unavailability hours reported in 4Q97 (Train 1) and 2Q99 (Train 2) were revised. The pump was declared out of service while preventive maintenance was performed on it's power supply bus. Per guidance provided in FAQ 145, this out of service time is not counted as unavailability time since the refueling pool was flooded as allowed by technical specifications. This change did not result in a threshold color change. The indicator remains Green.

Safety System Functional Failures (PWR)




Thresholds: White > 5.0

Notes

Safety System Functional Failures (PWR)	4Q/99	1Q/00	2Q/00	3Q/00	4Q/00
Safety System Functional Failures	0	0	0	0	2
Indicator value	3	2	2	0	2

Licensee Comments: none

Reactor Coolant System Activity




Thresholds: White > 50.0 Yellow > 100.0

Notes

Reactor Coolant System Activity	1/00	2/00	3/00	4/00	5/00	6/00	7/00	8/00	9/00	10/00	11/00	12/00
Maximum activity	0.001200	0.001200	0.001400	0.001500	0.002300	0.001900	0.001900	0.001900	0.002700	0.002600	0.002800	0.004000
Technical specification limit	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0
Indicator value	0.1	0.1	0.1	0.2	0.2	0.2	0.2	0.2	0.3	0.3	0.3	0.4

Licensee Comments: none

Reactor Coolant System Leakage




Thresholds: White > 50.0 Yellow > 100.0

Notes

Reactor Coolant System Leakage	1/00	2/00	3/00	4/00	5/00	6/00	7/00	8/00	9/00	10/00	11/00	12/00
Maximum leakage	0	0	0	0	0	0	0	0	0	0	0	0
Technical specification limit	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0	10.0
Indicator value	0	0	0	0	0	0	0	0	0	0	0	0

Licensee Comments: none

Drill/Exercise Performance



Thresholds: White < 90.0% Yellow < 70.0%


Notes

Drill/Exercise Performance	4Q/99	1Q/00	2Q/00	3Q/00	4Q/00
Successful opportunities	65.0	12.0	2.0	45.0	31.0
Total opportunities	68.0	14.0	2.0	47.0	33.0
Indicator value	96.2%	95.6%	95.1%	95.5%	95.6%

Licensee Comments:

3Q/00: The 3Q2000 ERO Drill and Exercise Performance Indicator is being revised. Three opportunities and successess are being removed due to the fact that the September excercise was too similar to the previous drill. The exercise was re-performed in the 4Q2000. This change did not result in a threshold color change.

ERO Drill Participation




Thresholds: White < 80.0% Yellow < 60.0%

Notes

ERO Drill Participation	4Q/99	1Q/00	2Q/00	3Q/00	4Q/00
Participating Key personnel	76.0	73.0	71.0	69.0	71.0
Total Key personnel	77.0	74.0	76.0	69.0	71.0
Indicator value	98.7%	98.6%	93.4%	100.0%	100.0%

Licensee Comments: none

Alert & Notification System




Thresholds: White < 94.0% Yellow < 90.0%

Notes

Alert & Notification System	4Q/99	1Q/00	2Q/00	3Q/00	4Q/00
Successful siren-tests	312	308	306	290	302
Total sirens-tests	312	312	312	312	312
Indicator value	97.2%	98.0%	98.4%	97.4%	96.6%

Licensee Comments: none

Occupational Exposure Control Effectiveness




Thresholds: White > 2.0 Yellow > 5.0

Notes

Occupational Exposure Control Effectiveness	4Q/99	1Q/00	2Q/00	3Q/00	4Q/00
High radiation area occurrences	0	2	0	0	0
Very high radiation area occurrences	0	0	0	0	0
Unintended exposure occurrences	0	0	0	0	0
Indicator value	0	2	2	2	2

Licensee Comments: none

RETS/ODCM Radiological Effluent




Thresholds: White > 1.0 Yellow > 3.0

Notes

RETS/ODCM Radiological Effluent	4Q/99	1Q/00	2Q/00	3Q/00	4Q/00
RETS/ODCM occurrences	0	0	0	0	0
Indicator value	0	0	0	0	0

Licensee Comments: none

Protected Area Security Performance Index




Thresholds: White > 0.080

Notes

Protected Area Security Performance Index	4Q/99	1Q/00	2Q/00	3Q/00	4Q/00
IDS compensatory hours	7.10	37.03	155.08	112.69	11.89
CCTV compensatory hours	0	0	0	0	0
IDS normalization factor	1.10	1.10	1.10	1.10	1.10
CCTV normalization factor	1.0	1.0	1.0	1.0	1.0
Index Value	0.009	0.010	0.014	0.016	0.016

Licensee Comments: none

Personnel Screening Program




Thresholds: White > 2.0 Yellow > 5.0

Notes

Personnel Screening Program	4Q/99	1Q/00	2Q/00	3Q/00	4Q/00
Program failures	0	0	0	0	0
Indicator value	0	0	0	0	0

Licensee Comments: none

FFD/Personnel Reliability



Thresholds: White > 2.0 Yellow > 5.0

Notes

FFD/Personnel Reliability	4Q/99	1Q/00	2Q/00	3Q/00	4Q/00
Program Failures	0	0	0	0	0
Indicator value	0	0	0	0	0

Licensee Comments: none

▲ [PI Summary](#) | [Inspection Findings Summary](#) | [Action Matrix Summary](#) | [Reactor Oversight Process](#)

Last Modified: March 28, 2002